

National Human Rights Commission

Diary No	150918/CR/2018	Case / File No	30145/24/12/2018-AD
Victim Name	PHULCHAND NISHAD	Registration Date	24/09/2018

Action List (Click on Action given in blue color to view details)

Action No.	Action	Authority	Action Date
5	Concluded and No Further Action Required		16/07/2021
4	Comments of Complainant Called for		03/12/2020
3	Conditional Summon	THE DISTRICT MAGISTRATE Collectorate Banda (U.P.)	03/12/2020
2	Sent to DG(I), NHRC	BANDA, UTTAR PRADESH	25/11/2020
1	Sent to DG(I), NHRC	BANDA,UTTAR PRADESH	28/09/2018

[Expand All Action List](#)[Action](#)**Action : Concluded and No Further Action Required(Action No 5)**

Action Date	16/07/2021
Authority	,
Proceeding	<p>This is a complaint received from Social & Human Right Activist in which it is indicated that one person died and four other injured due to electrocution while working on the 11 KV HT power line. It is alleged that the incident occurred due to negligence on the part of the concerned authority by not adhering to statutory safety measures. The complainant desires inquiry to affix responsibility on the erring officials and compensation to the next of kin of the victim. Taking cognizance, notice was directed to the concerned authorities. Pursuance thereto, the commission received report dated 22-12-2020 from the office of the Senior Superintendent of Police, District Gaya forwarding inquiry report of even date. As per the report, the deceased and other workers were working on the HT line when due to electrocution, one worker namely Sunil Yadav died on 12-07-2020. The police also registered UD No.4/2020 and postmortem was carried on the dead body. In the report dated 06-01-2021 received from South Bihar Power Distribution Company Ltd. Patna, it is stated that the workmen started working on the power line without information and instruction of the site engineer and thus came into contact with the live wire. It is also stated that the deceased and other four injured workers were given immediate relief of Rs.25,000/- apart from Rs.11,54,738/- disbursed under the Workman Compensation Policy by the contractor M/s. Bajaj Electricals Ltd. Since the injured workmen have been compensated under the Workmen Compensation Policy, no further indulgence is desirable. The case is therefore closed.</p>